Data current as of February 2010.

AQUA ILLINOIS-PHILO

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		0			8.87						
		A			A						
-	-	-	-	-	mid	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 09/16/09 from 208 FRANKS DRIVE
B.
C.
D.

BROADLANDS

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.6	360	231	1090	320	0	22	0	40	0	95	0
A	A	B	C	A	B	A	A	A	D	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 05/03/05 from WTP ON W END 2ND ST
B. 09/24/09 from 303 E 3RD
C. 01/03/06 from WTP ON W END 2ND ST
D. 07/25/05 from WTP ON W END 2ND ST

CHANUTE AFB

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	30	3	1027	94	0	102	0	0	0.5	59.3	0
A	B	C	B	B	C	B	B	B	D	B	B
-	-	-	-	-	-	mid	-	-	-	-	-
-	-	-	-	-	-	high	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 03/11/87 from WELL C2 BLDG 967
B. 08/02/93 from C PLANT
C. 07/16/08 from 1394 ABRAM DR
D. 07/27/93 from B PLANT

COUNTRY TYME ESTATES

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
6.67	0	158	560	24	0	8	0	0	0	43	0
A	B	C	B	B	C	B	B	B	D	B	B
mid	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/18/10 from WTP
B. 11/20/08 from WTP
C. 08/04/09 from LOT 43
D. 08/03/09 from WTP

COUNTRY VIEW ESTS MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	12.6	0	150	230	9.63	0	0	0	0	166	37
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	mid	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/22/08 from NORTH END OF PARK
B. 09/09/09 from LOT 06
C. 08/19/09 from NORTH END OF PARK
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/report

Data current as of February 2010.

DEWEY PWD

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0.72	55.9	800	772	98.2	3	34.4	0	0	0.292	12.4	0
A	A	B	A	A	B	A	A	A	C	A	A
-	-	mid	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 10/20/08 from WTP,2ND ST N OF TRKS
B. 09/17/09 from 3053 COUNTRY RD 900E
C. 07/12/10 from WTP,2ND ST N OF TRKS
D.

EAST SIDE MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
7.25	26.2	0	366	573	0	148	0	0	0	18.4	10.6
A	A	B	A	A	B	A	A	A	C	A	A
mid	-	-	-	mid	-	mid	-	-	-	-	-
-	-	-	-	-	-	high	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/18/08 from WELL 2 IS N OF MHP
B. 08/17/09 from 1938 CTY RD LOT20
C. 08/17/09 from WELL 2 IS N OF MHP
D.

EHLERS MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	55.34	0	144	989.1	0	35.7	0	0	0	10.22	64.78
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 02/04/08 from WEST PART OF PARK
B. 09/16/08 from 3711 N CGHM. LOT 31
C. 07/21/09 from WEST PART OF PARK
D.

FISHER

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	7.72	376	980	79.78	0	0	0	0	1.13	165.3	75.91
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/23/08 from WTP
B. 07/29/09 from 505 SOUTH FIRST ST
C. 07/13/10 from WPT
D.

FOUNTAIN VALLEY MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
14.5	0	0	461	0	0	0	0	0	0	160	15.4
A	B	C	B	B	C	B	B	B	D	B	B
mid	-	-	-	-	-	-	-	-	-	-	-
high	-	-	-	-	-	-	-	-	-	-	-
over	-	-	-	-	-	-	-	-	-	-	-

A. 04/20/10 from WTP IS AT STANDPIPE
B. 10/20/08 from WTP IS AT STANDPIPE
C. 07/14/09 from LOT 29
D. 07/14/09 from WTP IS AT STANDPIPE

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/report

Data current as of February 2010.

GIFFORD

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	75.5	1140	1450	0	0	0	0	0	0.972	25.8	36.6
A	A	B	A	B	B	A	A	A	c	A	A
-	-	mid	-	-	-	-	-	-	-	-	-
-	-	high	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 02/09/09 from NEW WATER PLANT
B. 07/14/09 from 203 EAST CHURCH
C. 07/12/10 from NEW WATER PLANT
D.

HERITAGE ESTATES MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		100			5						
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/30/07 from 1330 E SYCAMORE
B.
C.
D.

HOMER

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	133	0	0.379	869	0	63.7	0	0	0	62.9	49.2
A	A	A	A	A	A	A	A	A	A	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/29/10 from WELL 3 IS 0.25 MILES
B.
C.
D.

IL AMERICAN-CHAMPAIGN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2.03	436	0	231	996	0	34.9	0	0	0	36.4	0
A	A	A	A	A	A	A	A	A	A	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/15/10 from WELL 59 IN WEST WELL
B.
C.
D.

IVESDALE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	129	394	1310	0	0	0	0	0	1.29	33.4	14
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	a	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/12/09 from PLANT NEAR TOWER S
B. 04/01/10 from 402 FIFTH ST
C. 07/12/10 from PLANT NEAR TOWER S
D.

	Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch, and are accurate as of

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

Data current as of February 2010.

LONGVIEW

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.54	166	0	488	371	0	25.5	0	0	0	46	0
A	A	A	A	B	A	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/31/08 from WELL 1 IS INSIDE PLA
B. 04/14/08 from PLANT IS SW OF TOWN
C. 07/13/09 from PLANT IS SW OF TOWN
D.

LUDLOW

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	38	29	270	0	1	25	0	0	0	12	0
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/16/08 from PLANT IS NEAR TOWER
B. 08/05/09 from 245 S ORANGE ST
C. 07/23/09 from PLANT IS NEAR TOWER
D.

MAHOMET

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	29	410	770	11	0	0	0	0	1.1	120	37
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/26/09 from WTP
B. 09/04/09 from 1105 RIDGEWOOD RD
C. 07/23/09 from WTP
D.

OAKS OF ILLINOIS LLC MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	0	0	0	0	0	0	0	0	0	0	0
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 06/30/08 from DAVID MYRES LOT 25
B.
C.
D.

OGDEN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.57	104	0	334	0	0	40.4	0	0	0.845	17.2	0
A	A	A	A	B	A	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/18/08 from WELL 2 IS OUTSIDE PL
B. 05/28/08 from WTP, DOWNTOWN
C. 09/10/09 from WTP, DOWNTOWN
D.

	Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/report

Champaign County 5 OF 7 (Schedule "C")

Data current as of February 2010.

PENFIELD PWD

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0.65	405	0	404	0	0	17.5	0	0	0.212	51.6	0
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/21/08 from WTP IS ON THE EAST
B. 11/16/09 from WTP IS ON THE EAST
C. 07/20/09 from WTP IS ON THE EAST
D.

PLEASANT PLAINS MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
19.8	93.8	0	0	362	0	0	0	0	0	93.8	13.9
A	B	C	B	B	C	B	B	B	D	B	B
mid	-	-	-	-	-	-	-	-	-	-	-
high	-	-	-	-	-	-	-	-	-	-	-
over	-	-	-	-	-	-	-	-	-	-	-

A. 04/12/10 from WELL 1 IS W OF WELL
B. 10/15/08 from WELL 1 IS W OF WELL
C. 06/16/08 from LOT 4, RR 1
D. 07/20/09 from WELL 1 IS W OF WELL

RANTOUL

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1	130	21	0	1000	0	47	0	0	1.6	30	2.7
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 10/22/08 from SAMPLG PT FOR WELLS
B. 07/22/08 from 1052 LANCASTER DR
C. 07/20/09 from SAMPLG PT FOR WELLS
D.

ROYAL

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	50	815	284	0	0	75.8	0	0	0.182	13.5	0
A	A	B	A	C	B	A	A	A	D	A	A
-	-	mid	-	-	-	mid	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/06/08 from WELL 2 IS OUTSIDE PL
B. 06/22/10 from 405 DUITSMAN DR
C. 01/23/08 from WTP,EAST OF RR
D. 09/16/09 from WTP,EAST OF RR

SADORUS

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
17.6	218	0	435	1560	5.43	0	0	0	0	65.7	11
A	A	A	A	A	A	A	A	A	A	A	A
mid	-	-	-	mid	-	-	-	-	-	-	-
high	-	-	-	high	-	-	-	-	-	-	-
over	-	-	-	over	-	-	-	-	-	-	-

A. 09/22/09 from WELL 2 IS E OF 2ND A
B.
C.
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/report

Data current as of February 2010.

SANGAMON VALLEY PWD

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.01	110	0	0.325	1500	0	0	0	7	0	19.2	0
A	A	A	A	A	A	A	A	A	A	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 03/25/10 from WELL 1 IS INSIDE WEL
B.
C.
D.

SEYMOUR WATER DISTRICT

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	0	0	0	0	0	0	0	0	0	0	0
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/18/08 from 114 E CENTER
B.
C.
D.

SIDNEY

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
5	125	0	440	1565	0	34	0	0	0	71	16
A	A	B	A	A	B	A	A			A	A
mid	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 05/13/86 from WELL 2 50 FT SE OF P
B. 09/30/09 from 1 JAMES CT
C.
D.

THOMASBORO

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0.88	89.9	234	1.47	86.3	0	26.5	0	0	0.136	24.5	15.7
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/26/09 from WTP
B. 09/25/08 from 300 W COMMERCIAL
C. 08/24/09 from WTP
D.

TOLONO

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
55	393	100	270	3851	5	20	0			125	0
A	A	B	A	A	B	A	A			A	A
mid	-	-	-	mid	-	-	-	-	-	-	-
high	-	-	-	high	-	-	-	-	-	-	-
over	-	-	-	over	-	-	-	-	-	-	-

A. 4/29/86 from WELL 11
B. 09/29/09 from 507 E LOCUST
C.
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/report

Data current as of February 2010.

TRIANGLE MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
10.5	97.6	734	553	79	0	51.9	0	0	0	34.5	0
A	B	C	B	B	C	B	B	B	D	B	B
mid	-	mid	-	-	-	-	-	-	-	-	-
high	-	-	-	-	-	-	-	-	-	-	-
over	-	-	-	-	-	-	-	-	-	-	-

A. 04/14/10 from TP01 - TREATMENT PLANT
B. 10/20/08 from TP01 - TREATMENT PLANT
C. 08/09/09 from TRIANGLE MHP LOT 39
D. 07/12/10 from TP01 - TREATMENT PLANT

U OF I CHMPAIGN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	0	0	0	0	0	0	0	0	0	0	0
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/06/08 from 1800 SOUTH WRITHT ST
B.
C.
D.

YOUNGS HILLCREST HMP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	61.2	0	418	827	0	53.5	0	0	0	15.4	0
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 12/02/08 from WELL 1
B. 07/29/08 from 04 CAROLYN YOUNGS
C. 04/12/10 from WELL 1
D.

CHERRY ORCHARD APTS

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.3	180	0	120	760	0	43	0	0	0	28	0
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/02/05 from WTP
B. 06/07/06 from APT 28
C. 07/09/06 from WTP
D.

D AND R APTS

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
4.1	160	0	250	1100	0	34	0	0	0	24	81.5
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 01/28/02 from WELL 1 IS ON W SIDE
B. 07/24/03 from 2700 N APT 56
C. 10/21/03 from WELL 1 IS ON W SIDE
D.

	Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/report