Data current as of May 2010.

AQUA IL-HIGHLAND ESTATES

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1	100	18	830	400	1	10	0	0	0.1	26	35
A	A	B	A	A	B	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/15/09 from WELL 4 CHLOR PR TKS
B. 09/17/08 from 1003 PAUL DR.
C.
D.

AQUA IL-KANKAKEE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	10	0	1100	16	0	4.7	0	0	2.4	8.2	69
A	A	B	A	A	B	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/15/09 from WTP
B. 08/22/07 from 690 VICKSBURG
C.
D.

AQUA IL-SKYLINE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	10	5	700	240	0	8	0	7	0	35	140
A	A	B	C	A	B	A	A	A	D	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 11/24/06 from WELL 1 CHLOR FL RES
B. 08/27/09 from 3742 LAKEVIEW DR.
C. 12/14/07 from WELL 1 CHLOR FL RES
D. 12/08/03 from WELL 1 CHLOR FL RES

AQUA IL-SUN RIVER TERRACE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2	15	300	870	840	0	64	0	13	0	25	130
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/14/09 from DISCH PIPE OFWELL1 2
B. 09/18/07 from 7425 E. FIRST ST.
C. 10/07/08 from WELL 2 AT END CUL DE
D.

BARBERRY ACRES MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	78.7	0	429	276	0	0	0	0	0	25.7	29.4
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 10/22/08 from WELL 1 ON S SIDE OF
B. 08/12/09 from LOT F-11
C. 04/08/10 from WELL 1 ON S SIDE OF
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard

Data current as of May 2010.

BILLS MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2	12	260	310	430	2	99	0	0	0	56	85
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	mid	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 05/05/08 from WELL 1
B. 08/18/09 from 10557 N. RTE. 50, HO
C. 12/15/03 from WELL 1
D.

BUCKINGHAM

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	19.4	128	1120	121	0	0	0	0	0	127	10.9
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 09/21/09 from WELL 6
B. 09/23/09 from ETHEL ST., CUMMINS
C. 12/16/09 from WELLS 3 5
D.

COUNTRYSIDE MOBILE HOME ESTS

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	100	190	270	370	0	10	0	0	0	160	70
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/05/08 from TREATMENT PLANT
B. 07/17/09 from LOT C6
C. 05/07/07 from WELL 1, E OF LOT S1
D.

HERSCHER

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	0	0	285	0	0	0	0	0	0	194	232
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 12/01/09 from WTP WELL 7 8
B. 09/23/09 from 184 N. ELM
C. 12/08/09 from WTP WELL 7 8
D.

HOPKINS PARK

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0.13	36	140	1	90.4	4.6	6	0	1.24	0	24.9	29.4
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 10/22/07 from WELLS 1, 2
B. 09/23/09 from 12256 E. CENTRAL ST.
C. 10/28/09 from WELLS 1, 2
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard

Data current as of May 2010.

LAKE SHANNON

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0.59	16.7	0	920	0	0	0	0	0	0.229	38.8	623
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	mid
-	-	-	-	-	-	-	-	-	-	-	high
-	-	-	-	-	-	-	-	-	-	-	over

A. 01/11/10 from WTP NEAR WELL2
B. 08/04/09 from LOT 56 BILLY MCGALLI
C. 04/12/10 from WTP NEAR WELL2
D.

MANTENO MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2.8	16	3.6	550	310	0	5.4	0	0	0	23	49
A	A	B	C	A	B	A	A	A	D	A	C
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/07/08 from WELL 1
B. 07/18/09 from LOT 2
C. 04/09/08 from WELL1
D. 04/09/08 from WELL 2 PTL ADPTR E O

MOMENCE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	23	270	940	13	3.6	2.6	0	9.7	1.8	6.6	67
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/20/09 from WELL 4
B. 07/14/09 from 327 PINE ST.
C. 10/20/09 from WELL 4
D.

PEMBROKE TOWNSHI

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		0	940		0						
		A	B		A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 06/13/06 from 13253 E. 2690 S. RD.
B. 10/02/07 from E SIDE MAIN OPP
C.
D.

REDDICK

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0.246	27	0	1740	5	0	890	0	0	0.374	356	269
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	mid	-	-	-	-	mid
-	-	-	-	-	-	high	-	-	-	-	-
-	-	-	-	-	-	over	-	-	-	-	-

A. 01/08/08 from WELL 1
B. 12/31/07 from WELL 1
C. 04/13/10 from WELL 1
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch, and are accurate as of November 2009.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

Data current as of May 2010.

RIVERCREST MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	32.1	132	544	121	0	0	0	0	0	44.2	104
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/15/08 from TREATMENT PLANT
B. 09/23/09 from 1084 E. 5800 S.
C. 08/18/09 from TREATMENT PLANT
D.

SKYVIEW SBDV

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	22.5	0	570	233	0	0	0	0	0.123	33.1	42.3
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 06/10/09 from FRM WELL 1 TO DS
B. 09/10/09 from LOT 26 63N 3530 E RD
C. 11/23/09 from FRM WELL 1 TO DS
D.

ST ANNE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2.37	23.9	0	21.7	244	0	0	0	0	0	33	141
A	A	B	A	C	B	A	A	A	B	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/28/09 from WELL 3
B. 10/22/08 from WELL 3 AT GRANT FI
C. 04/12/10 from WELL 3
D.

SUNNY ACRES MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2	16	4.1	490	100	0	9	0	0	0	10	54
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/07/08 from TREATMENT PLANT
B. 07/17/09 from 200 FRANKLIN
C. 05/07/07 from TREATMENT PLANT
D.

WINDMILL ESTATES

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2.08	22	0	244	1160	0	0	0	0	0	18	96.9
A	A	B	A	A	B	A	A	A	A	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 10/21/09 from WELL 2
B. 09/10/09 from LOT C1
C.
D.

	Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard

Data current as of May 2010.

GRANT PARK

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
9.5	180	10	101	9200	0	66	0	0	0	17	66
A	B	C	B	B	D	B	B	B		B	B
mid	-	-	-	mid	-	-	-	-	-	-	-
high	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 12/08/03 from WELL 3
B. 07/16/01 from WELL 4
C. 09/22/97 from WELL 4
D. 07/08/96 from WELL 3

MANTENO

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.3	25	0	320	0	0	0	0	25	0.18	26	85.3
A	A	A	A	A	A	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 03/30/07 from WELL 7
B.
C.
D.

MAPLE RIDGE MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		0			0						
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 06/30/08 from 19 MAPLE RIDGE
B.
C.
D.

MAPLE VALLEY MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		47			0						
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/29/08 from 142 VERMONT DRIVE
B.
C.
D.

OAK RIDGE MHP

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A.
B.
C.
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard