Vermilion County 1 OF 4 (Schedule "A")

Data current as of May 2010.

ALLERTON

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
8.29	75.9	0	194	1240	0	50.6	0	0	0	9.11	81.2
A	A	A	A	A	A	A	A	A	A	A	A
mid	-	-	-	mid	-	-	-	-	-	-	-
high	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	over	-	-	-	-	-	-	-

A. 01/26/10 from WELL 3 IS WEST WELL
B.
C.
D.

ALVAN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
31	224	0	560	2150	0	69.7	0	0	0	39.7	11.9
A	A	A	A	A	A	A	A	A	A	A	A
mid	-	-	-	mid	-	-	-	-	-	-	-
high	-	-	-	high	-	-	-	-	-	-	-
over	-	-	-	over	-	-	-	-	-	-	-

A. 01/26/10 from WELL 1 IS INSIDE PL
B.
C.
D.

AQUA IL-INDIANOLA

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	230	230	990	330	2	100	0	12	0	26	77
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	mid	-	-	-	-	-
-		-	-	-	-	high	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/15/09 from TP02 TREATMENT PLANT
B. 06/20/07 from 104 E WASHINGTON
C. 04/08/09 from TP02 TREATMENT PLANT
D.

AQUA IL-VERMILION COUNTY

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	4	22	880	0	0	0	0	0	7.5	6.7	32
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	mid	-	-
-	-	-	-	-	-	-	-	-	high	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 01/15/10 from PURIFICATION PLANT
B. 09/10/08 from 30 LAMM ST
C. 04/08/09 from PURIFICATION PLANT
D.

BISMARCK COMM. WATER DISTRICT

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
6.52	175	135.7	992	0	0	17.6	0	0	0	109	20.4
A	A	B	A	A	B	A	A	A	C	A	A
mid	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/20/09 from WTP
B. 08/11/08 from JAEGER 519 CHICAGO
C. 04/19/10 from WTP
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard

Data current as of May 2010.

CATLIN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		0			0						
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 07/11/07 from 104 DREW DRIVE
B.
C.
D.

EAST LYNN COMM. WATER SYSTEM

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
2.46	20.3	0	192	135	0	38.3	0	0	0	54	258
A	A	B	A	A	B	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	-	-	mid
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 09/30/09 from WTP IS W OF MAIN RD
B. 09/30/09 from REX GREENE PO BOX EA
C.
D.

FAIRMOUNT

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	68.9	0	241	72.9	0	0	0	0	0	43.4	88.6
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/25/09 fromWTP AT HIGH SCHOOL
B. 08/31/07 from 402 E STATE
C. 04/19/10 from WTP AT HIGH SCHOOL
D.

FITHIAN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.88	82.5	0	1290	0	0	0	0	0	0	14.1	0
A	A	B	A	A	B	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 09/16/09 from WELLS 5 6
B. 09/30/07 from 209 S ADAMS
C.
D.

GEORGETOWN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	57	94	1200	0	1.7	0	0	0	3.1	22	42
A	A	B	A	A	B	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 10/13/09 from PUMPING STATN TO DS
B. 08/15/07 from 118 E 8TH ST
C.
D.

	Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard

Vermilion County 3 OF 4 (Schedule "A")

Data current as of May 2010.

HOOPESTON

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
6.2	86	220	1100	510	0	29	0	5.6	0.11	24	30
A	A	B	A	A	B	A	A	A	C	A	A
mid	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/03/09 from WTP CRNR OF 4TH MN
B. 08/04/08 from 426 N 4TH ST APT C
C. 04/13/09 from WTP CRNR OF 4TH MN
D.

OAKWOOD

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	37	1000	310	15	14	0	0	0	7.9	10	56
A	A	B	A	A	B	A	A	A	C	A	A
-	-	mid	-	-	mid	-	-	-	mid	-	-
-	-	high	-	-	high	-	-	-	high	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 06/03/09 from 1 MILE S OF OAKWOOD
B. 08/20/07 from 380 HORIZON DR
C. 04/30/08 from 1 MILE S OF OAKWOOD
D.

OLIVET PWD

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	0	126.8	0	0	11.21	0	0	0	0	0	0
		A			A						
-	-	-	-	-	mid	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 09/25/07 from 15535 COLLEGE AVE
B.
C.
D.

POTOMAC

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
1.31	15.5	0	1040	113	0	0	0	0	0.942	82.2	572
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	mid
-	-	-	-	-	-	-	-	-	-	-	high
-	-	-	-	-	-	-	-	-	-	-	over

A. 08/24/09 from WTP N OF RT136 VERMI
B. 09/05/07 from 106 S WILSON
C. 05/18/09 from WTP N OF RT136 VERMI
D.

RANKIN

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	144	126.1	1220	998	0	46.8	0	0	0	43.1	10.3
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	mid	-	-	-	-	-	-	-
-	-	-	-	high	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 9/23/09 from PLANT IS W OF RT.49
B. 09/27/07 from 206 W 7TH AVENUE
C. 05/20/09 from PLANT IS W OF RT.49
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch, and are accurate as of November 2009.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

Data current as of May 2010.

RIDGE FARM

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	120	415.7	830	0	0	12	0	0	0	5.6	3
A	A	B	A	A	B	A	A	A	C	A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/18/09 from WTP 1 MILE S OT TOWN
B. 09/12/07 from 308 VIRGINIA DR
C. 04/15/09 from WTP 1 MILE S OT TOWN
D.

ROSSVILLE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
3	120	630	370	14	0	38	0	5	0	19	12
A	B	C	B	A	C	B	B	B	B	B	B
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 04/06/10 from WTP
B. 02/10/09 from WELL 4A
C. 07/30/07 from 204 HARRISON ST
D.

SIDELL

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	18.9	0	224	0	0	0	0	0	6.11	5.37	64.3
A	A	A	A	A	A	A	A	A	A	A	A
-	-	-	-	-	-	-	-	-	mid	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 02/23/10 from WELL 3 IS ON SE CORN
B.
C.
D.

VERMILION GROVE WATERWORKS

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
		0			0						
		A			A						
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 09/17/08 from STEVE PEARSN BOX135
B.
C.
D.

WESTVILLE

Arsenic	Barium	Copper	Fluoride	Iron	Lead	Mangan.	Mercury	Nickel	Nitrate-N	Sodium	Sulfate
0	18	22	933	0	0	0	0	0		0	54.2
A	A	B	A	A	B	A	A	A		A	A
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

A. 08/04/97 from CHEMICAL RESULTS
B. 06/17/08 from 29 CHAMPAIGN ST
C.
D.

1/2	5	1000	650	2000	500	7.5	75	1	50	5	4500	250
3/4	7.5	1500	975	3000	750	11.25	100	1.5	75	7.5	6750	375
mcl	**10**	**2000**	**1300**	**4000**	**1000**	**15**	**150**	**2**	**100**	**10**	**9000**	**500**

Contaminants in light gray boxes are measured in micrograms per liter (µg/L). Contaminants in dark gray boxes are measured in milligrams per liter (mg/L).

°For simplicity, only one sample of lead and copper is given per water system. Multiple samples are usually taken from several different locations within each water system. Since the concentration levels vary according to location, we encourage you to visit the Illinois EPA website to determine lead and copper levels nearest your home. All records were compiled from the Illinois EPA Drinking Water Watch.

This form made available by Aquality Solutions® specifically for use with their Water Report Card and may not be republished without Aquality Solutions' consent.

The full Aquality Solutions Water Report Card with data on eight East-Central Illinois counties can be found at http://www.4water1.com/reportcard